State 1
Cust 1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106529
Permit No.
Basin Ø64

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60223

1. OWNER David ITZA
MAILING ADDRESS P.O. Box 578
Battle MTN NV 89820

ADDRESS AT WELL LOCATION 465 26th ST
Battle MTN 89820
Subdivision Name: Malone County: Landon

2. LOCATION NW ¼ SW ¼ Sec 24 T 32 N/S R 44 E
PERMIT/WAIVER No. 011-040-~~[illegible]~~
Issued by Water Resources
Parcel No. 04

Latitude ~~[illegible]~~
Longitude ~~116.974262~~
UTM E 502172 ~~NAD 27~~
N 4497 ~~494~~ 750 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Green Clay		5	20	15
Tan Clay		20	30	10
Blue Clay		30	80	50
Rocky Tan Clay		80	100	20
Gravel + Blue Clay		100	120	20

N 40.632487
W 116.974317 NAD27

Date started: 5-16, 20 08
Date completed: 5-17, 20 08

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation SAWed
Size of perforation 3/16 x 3
From 100 ft feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 5 to 55 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 95 to 120 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 55 to 95 ☐ Pumped ☒ Poured
Type: 3/8 "

7. Water Level
Static water level: 30 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	50+	[illegible]	[illegible]

STATE ENGINEERS OFFICE
2008 JUL -7 PM 2:05
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor

Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807

Signed Joe Boggio
By driller performing actual drilling on site or contractor Joe Boggio
Date

(Rev 06-08)

USE ADDITIONAL SHEETS IF NECESSARY