STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106530
Permit No.
Basin 107

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62868

1. OWNER NORM MC MURRAY
MAILING ADDRESS # 16 MEADOWLARK LN
NW SMITH VALLEY, NV 89444

ADDRESS AT WELL LOCATION # 16 MEADOWLARK LN
SMITH VALLEY, NV 89444
Subdivision Name: County: Lyon

2. LOCATION ~~SW~~ ¼ SW ¼ Sec 30 T 12N N/S R 24 E
PERMIT/WAIVER No. 09-041-05 Parcel No.
Issued by Water Resources

Latitude 38.87419*N
Longitude 119.34472*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SET UP OVER OLD WELL		0	140	140
AND WASHED OUT WITH				
FRESH WATER FROM				
107' TO 140'				
CAME UP TO 60' AND BLEW				
CLEAN				
N 38.874277				
W 119.343727 NAD27				

Date started: 19-Jun, 20 08
Date completed: 19-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
n/a	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	140

Perforations:
Type of perforation N/A
Size of perforation N/A
From N/A feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 20 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	10	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael L Hack
by driller performing actual drilling on site or contractor
Date 06/20/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2008 JUL -9 AM 10:29
STATE ENGINEERS OFFICE