


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 106044
Permit No. _____
Basin 087



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62084

1. OWNER Jerry Sullivan ADDRESS AT WELL LOCATION 10800 Shay Ln. Reno, NV 89511
MAILING ADDRESS 10800 Shay Ln. Reno, NV 89511

Subdivision Name: Fairview Farms #2 County: Washoe
2. LOCATION SE 1/4 SW 1/4 Sec 12 T 18N N/S R 19 E Latitude N 39 26.185 UTM E NAD 27
PERMIT/WAIVER No. Dom 08-003 230-092-14 Longitude W 119 47.990 N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor
5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| Clay | | 0 | 10 | 10 |
| Cobble | | 10 | 15 | 5 |
| Sandy Clay | | 15 | 58 | 43 |
| Bolder | | 58 | 67 | 9 |
| Clay | | 67 | 70 | 3 |
| Volcanic Rock | | 97 | 97 | |
| Clay | | 97 | 105 | 8 |
| Hard Rock | | 105 | 168 | 63 |
| Soft Rock | | 168 | 183 | 15 |
| Hard Rock | | 183 | 225 | 42 |
| Soft Rock | | 225 | 247 | 22 |
| Hard Rock | | 247 | 261 | 14 |
| Clay | | 261 | 276 | 15 |
| Hard Rock | | 276 | 297 | 21 |
| T. D. 297 | | | | |
| <u>N 39.436524</u> | | | | |
| <u>W 119.798929 NAD27</u> | | | | |

9. WELL CONSTRUCTION

| | | | |
|--------------------------|-----------------|-----------------|-----------------|
| Depth Drilled | <u>297</u> Feet | Depth Cased | <u>297</u> Feet |
| HOLE DIAMETER (BIT SIZE) | | | |
| | From | To | |
| <u>11</u> Inches | <u>0</u> Feet | <u>110</u> Feet | |
| <u>8 3/4</u> Inches | <u>110</u> Feet | <u>297</u> Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.9</u> | <u>188</u> | <u>+2</u> | <u>197</u> |

Perforations:

| Type of perforation | Size of perforation | mill slot |
|---------------------|---------------------|-----------------|
| | | <u>3/32 x 3</u> |
| From <u>157</u> | feet to <u>177</u> | feet |
| From <u>217</u> | feet to <u>257</u> | feet |
| From <u>277</u> | feet to <u>297</u> | feet |

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured

Cement Grout 0 to 100 Pumped Poured

Concrete Grout to _____ Pumped Poured

≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 100 to 291 Pumped Poured

Type: _____

Bentonite Chips: Yes No to _____ Pumped Poured

Type: _____

7. Water Level
Static water level: 41 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>60</u> | <u>100</u> | |
| | <u>100+</u> | <u>150</u> | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service LLC
Contractor

Address P.O. Box 60130 Reno, NV 89506
Contractor

Nevada contractor's license number 5387C
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources 2121
the on-site driller

Signed Larry Welch
By driller performing actual drilling on site of contractor

Date 7/15/2008

RECEIVED
 JUL 21 PM 1:31
 STATE ENGINEERS OFFICE

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY