

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 107

NOTICE OF INTENT NO. 620.66

1. OWNER Les Smith ADDRESS AT WELL LOCATION White Mtn Road
 MAILING ADDRESS White Mtn Road Schurz, NV 89429
 2. LOCATION NE 1/4 NW 1/4 Sec 15 T. 13(N) S R 27 E Mineral County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravels + Sand</u>		<u>0</u>	<u>57</u>	<u>57</u>
<u>Clay</u>			<u>57</u>	<u>73</u>
<u>Gravels + Sands</u>		<u>73</u>	<u>104</u>	<u>31</u>
<u>Clay</u>		<u>104</u>	<u>117</u>	<u>13</u>
<u>Gravels + Sands</u>		<u>117</u>	<u>130</u>	<u>13</u>
<u>WGS 84</u>				
<u>N38° 59.659</u>				
<u>W118° 57.167</u>				
<u>N38.994410</u>				
<u>W118.951808 NAD27</u>				

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 100 Feet
9 7/8 Inches 100 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>PVC</u>	<u>Sch 40</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>13#</u>	<u>.188</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>PVC</u>	<u>Sch 40</u>	<u>20</u>	<u>130</u>

Perforations:
 Type perforation 52 wad
 Size perforation 1/8" x 3"
 From 103 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 130 feet

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc. Contractor

Date started 6-10, 2008
 Date completed 6-16, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>25</u>	<u>4</u>	<u>4</u>

Address PO Box 599 Contractor
Silver Springs, NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2346
 Signed J.B. [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-24-08