STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106578
Permit No.
Basin 092A

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **60632**

1. OWNER **George Zatarain**
MAILING ADDRESS **1321 N. McCarran Sparks, NV.89431**

ADDRESS AT WELL LOCATION **13910 Red Rock Rd.**
Reno, NV. 89506
Subdivision Name: *County:* **Washoe**

2. LOCATION **SW¼SW¼** Sec**06**T**21**N/ R**19**E
PERMIT/WAIVER NO. **N/A** **079-331-07**
Issued by Water Resources Parcel. No.

Latitude **39.71846** UTM E ☐ NAD 27
Longitude **119.90236** N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other **mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG		0	3	3
Sandy, Brown Clay		3	50	47
DG Clay		50	225	175
Sandy, Brown Clay		225	290	65
Brown Clay		290	330	40
DG		330	350	20
Brown Clay, Little DG		350	430	80
DG		430	570	140
Sandy Brown Clay		570	580	10
DG	X	580	600	20
DG Clay		600	660	60
DG	X	660	740	80
Sandy Brown Clay		740	760	20
DG	X	760	860	100
Brown Clay		860	890	30
N 39.718557				
W 119.901331 NAD27				

Date started: 2-08, 20 08
Date completed: 3-26, 20 08

7. *Water Level*
Static water level: **314** feet below land surface
Artesian Flow: **None** G.P.M. **None** P.S.I
Water Temperature: **Cool** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	100	645	2 hr

9. *WELL CONSTRUCTION*
Depth Drilled **890** Feet Depth Cased **890** Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	890	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	.188	-1	890

Perforations:
Type of perforation **Mill Slot**
Size of perforation **.060**
From **580** feet to **600** feet
From **660** feet to **740** feet
From **760** feet to **860** feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 70 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 70 to 890 ☐ Pumped ☒ Poured
Type: **3/8" Pea Gravel**
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Miller & Son's Drilling** (CONTRACTOR)
Address **P.O. Box 8056** (CONTRACTOR)
Reno, NV. 89507
Nevada contractor's license number issued by the *State Contractor's Board* **37915**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **1418**
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 4-21-08

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com