STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106591
Permit No.
Basin 0084

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60246

1. OWNER Timothy Jordan
MAILING ADDRESS 5155 Pasture View Rd.
SW SW Reno, NV 89510

ADDRESS AT WELL LOCATION 115 Chiefton Dr. Reno Nevada 89510
Subdivision Name County

2. LOCATION ~~NE~~ ¼ ~~SE~~ ¼ Sec ~~8~~ T 22N N/S R 21 E
PERMIT/WAIVER No. 1 076-470-06-14
Issued by Water Resources Parcel No.

Latitude N39.79852
Longitude W119.57935
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Red Volcanic rock		3	117	114
gray clay		117	158	41
DG		158	195	37

N 39.798611
W 119.578334 NAD27

Date started: 17-Mar, 20 08
Date completed: 21-Mar, 20 08

9. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	195	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	188	+2	195

Perforations:
Type of perforation Factory mill slot
Size of perforation 3/32
From 175 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout 0 to 50 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 195 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 20 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	50	
30	100	
50	195	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc
Contractor
Address 4850 Joule St. Suite A5
Contractor
Reno, NV 89502
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 2/13/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY