

Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin **137A**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO **56902**

1. OWNER **Dave Crowford** ADDRESS AT WELL LOCATION **Corner of Gattwood Creek Rd and Arc Dome Rd Siny Valley**  
 MAILING ADDRESS **Box 181 Tonopah NV 89049**

2. LOCATION **SW 1/4 SW 1/4 Sec 12 T 6 R 40 E NYE** County  
 PERMIT NO. **812-401-09** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand-boulders		0	80	80
Clay sand		80	85	5
Sand Gravel-Boulders	X	85	190	105
Clay		190	195	5

WGS 84  
 N 38° 23' 24" E  
 W 117° 26' 52" E

2008 SEP -8 PM 12:20  
 STATE ENGINEERING OFFICE

N 38.397538  
 W 117.441091 NAD27

8. WELL CONSTRUCTION  
 Depth Drilled **195** Feet Depth Cased **195** Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 195  
 11 Inches Feet 195 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	195

Perforations:  
 Type perforation **59W cut**  
 Size perforation **1 7/8 x 6"**

From **5.5** feet to **7.5** feet  
 From **9.5** feet to **11.5** feet  
 From **13.5** feet to **18.5** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal **50'**  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From **50** feet to **195** feet

9. WATER LEVEL  
 Static water level **88** feet below land surface  
 Artesian flow  G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature **Cold** °F Quality **good**

Date started **8-26-08**, 20  
 Date completed **8-27-08**, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>40</b>		<b>2</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Davis Drilling and Pumps** Contractor  
 Address **HK 61 Box 54** Contractor  
**Hiko NV 89017**

Nevada contractor's license number issued by the State Contractor's Board **0028966**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1191**

Signed **Mike Davi**  
 By driller performing actual drilling on site or contractor  
 Date **9-4-08**