

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 106640

Permit No. \_\_\_\_\_

Basin 087

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60990

1. OWNER Diane & Max McCombs ADDRESS AT WELL LOCATION 5305 Hoge Rd.  
MAILING ADDRESS 5305 Hoge Rd. Reno, NV 89506  
Reno NV 89506 Subdivision Name: \_\_\_\_\_ County: Washoe

2. LOCATION SW 1/4 NW 1/4 Sec 27 T 20N N/S R 19 E Latitude 39.57192 UTM E  NAD 27  
PERMIT/WAIVER No. DOM 05-00 Parcel No. 082-361-60 Longitude 119.84413 N  NAD 83/WGS 84  
Issued by Water Resources

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay cobbles		0	13	
green and red rocks		13	48	
gray clay		48	72	
hard rock		72	193	
broken rock	X	193	215	
N39.572010 W119.844104 NAD27				
2008 AUG 25 PM 1:56 STATE ENGINEER'S OFFICE				

9. WELL CONSTRUCTION

Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

From	To	From	To
10 5/8	0	60	60
8 3/4	60	215	215

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	+2	215

Perforations:

Type of perforation factory

Size of perforation 3/32

From 195 feet to 215 feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured

Cement Grout 0 to 50  Pumped  Poured

Concrete Grout to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 215  Pumped  Poured

Type: \_\_\_\_\_

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

7. Water Level

Static water level: 120 feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: cool °F

Quality: \_\_\_\_\_

Date started: 16-Jul 20 08

Date completed: 21-Jul 20 08

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	30	
40	55	
50+	95	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc  
Contractor

Address 4850 Joule St. Suite A5  
Contractor

Reno, NV 89502

Nevada contractor's license number issued by the State Contractor's Board 14170

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 7/22/2008