

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 106646
Permit No. _____
Basin 110.B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61619

1. OWNER John Daniels ADDRESS AT WELL LOCATION Walker Lake
MAILING ADDRESS #7 Raglan Circle
Carson City, NV 89701

2. LOCATION NE 1/4 SW 1/4 Sec 16 T 9 N/S R 29 E Latitude N38.63649 UTM E NAD 27
PERMIT/WAIVER No. 006-11-009 Longitude W118.75331 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____ Subdivision Name: _____ County: Mineral

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Cobbles & Clay		0	25	25
Cobbles		25	40	15
Consolidated Gravels		40	155	115
This well did not produce any water with the air lift. The customer wants to let it set to see if any water comes in eventually.				
2008 SEP 1 PM 12:54 STATE ENGINEERING DIVISION				
N38.63649 W 118.75331 NAD 83				

8. WELL CONSTRUCTION				
Depth Drilled	155	Feet	Depth Cased	155
HOLE DIAMETER (BIT SIZE)				
From		To		
14	Inches	0	Feet	155
	Inches		Feet	
	Inches		Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	155
Perforations:				
Type of perforation	Mill Slot			
Size of perforation	0.09			
From 100	feet to	155	feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
Surface Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Seal Type:				
Depth of Seal	100	<input type="checkbox"/> Neat Cement		
Placement Method:	<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Cement Grout		
	<input type="checkbox"/> Poured	<input type="checkbox"/> Concrete Grout		
Gravel Packed: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
From 100	feet to	155	feet	

9. WATER LEVEL
Static water level by None feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada Inc dba Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4975 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 56797
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed Cheryl Jaynes - Office
By driller performing actual drilling on site or contractor
Date 9/9/2008

Date started 7/29/2008, 20 08
Date completed 8/1/2008, 20 08

7. WELL TEST DATA			
TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
0			