

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59934

1. OWNER Roy Fought ADDRESS AT WELL LOCATION N38.863528
 MAILING ADDRESS Box 242 Land NV 89317 N38° 51' 48.7" W 115° 00' 27.2" NAD27
 2. LOCATION NW 1/4 NE 1/4 Sec. 33 T. 12 N/S R L2 E White Pine County
 PERMIT NO. N/A Issued by Water Resources 006-014-03 Parcel No. Land town site Plat Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay		0	30	
Sand	water	30	31	1
Clay		31	36	
gravel	water	36	37	1
Clay		37	52	
gravel	water	52	53	1
Clay		53	57	
gravel	water	57	58	1
Clay		58	65	
gravel	water	65	66	1
Clay		66	79	
gravel	water	79	82	3
Clay		82	90	
gravel	water	90	90.5	.5
Clay		90.5	100	
gravel	water	100	102	2
Clay		102	104	

Original 1" well was 42' 8" deep
 I pull it out 31' 6" of casing
 I am left out and deepened to 104'

RECEIVED
 2008 AUG 22 AM 10:00
 STATE ENGINEERS DIVISION

8. WELL CONSTRUCTION
 Depth Drilled 104 Feet Depth Cased 104 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 104 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	12.9	1.88	-1	19
6		Sch. 40 PVC	19	104

Perforations:
 Type perforation Factory Slotted
 Size perforation .032
 From 60 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 104 feet

9. WATER LEVEL
 Static water level 28' 8" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started July 10, 2008
 Date completed July 24, 2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	21'	1 hr

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor
 Address Box 64 Land NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Osman Maynard
 By driller performing actual drilling on site or contractor
 Date Aug 18 - 08