STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10621
Permit No.
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62901

1. OWNER BEVERLY AND STEVE WOLFE
MAILING ADDRESS 815 BELLWOOD DR APT 48
SW SPOKANE WA 99218

ADDRESS AT WELL LOCATION 343 SAM CLEMENS
DAYTON, NV 89403
Subdivision Name: County: Storey

2. LOCATION ~~NW~~ ¼ SE ¼ Sec 30 T 17N N/S R 22 E
PERMIT/WAIVER No. NE 003-262-15
Issued by Water Resources Parcel No.

Latitude 39.31239°N
Longitude 119.55487°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8" WELL		+2	215	213
BROWN CLAY		215	231	16
COBBLES AND GRAVELS		231	269	38
BROWN CLAY		269	274	5
FRACTURED GRAVELS	XX	274	305	31

Date started: 11-Aug, 20 08
Date completed: 15-Aug, 20 08

RECEIVED 2008 AUG 22 AM 10:36 STATE ENGINEER'S OFFICE

7. Water Level
Static water level: 190' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	60	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 305 ~~90~~ Feet Depth Cased 305 ~~90~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	215	Feet	305	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	205	305

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3X3/32
From 285 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPTIAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 08/18/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

N 39.312476
W 119.553862 NAD27