STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10da59
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62660

1. OWNER **Graciela Torre**
MAILING ADDRESS **8695 Grass Valley Road**

ADDRESS AT WELL LOCATION **8695 Grass Valley Road**
Winnemucca, NV 89445
Subdivision Name: *County:* **Humboldt**

2. LOCATION NE ¼ SW ¼ Sec24T35N/ R37E
PERMIT/WAIVER NO. **014-102-10**
Issued by Water Resources Parcel. No.

Latitude **N40°89098** UTM E ☐ NAD 27
Longitude **W117°76623** N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		**125**	**140**	**15**
course gravel & sand	**X**	**140**	**155**	**15**
Cobles		**155**	**160**	**5**
Clay		**160**	**170**	**10**
course sand/gravel	**X**	**170**	**215**	**45**

N40.891076
W 117.765267 NAD27

Date started: **August 1**, 20 **08**
Date completed: **August 2**, 20 **08**

2008 AUG 11 PM 12:22
STATE ENGINEER'S OFFICE

7. *Water Level*
Static water level: **126** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **Cool** °F
Quality: **Good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		**3**

9. *WELL CONSTRUCTION*
Depth Drilled **215** Feet Depth Cased **215** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	**125** Feet	**215** Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	**9**	**188**	**115**	**215**

Perforations:
Type of perforation **Factory Cut**
Size of perforation **3/32 x 4**
From **175** feet to **215** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* **021467**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2083**
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date **August 8, 2008**

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com