

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106060
Permit No. _____
Basin Ø71

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.300

APN 10-557-41

NOTICE OF INTENT NO. 62742

1. OWNER Nevada Home Modular ADDRESS AT WELL LOCATION 7535 Beas View Dr
MAILING ADDRESS 346 7th st Winnemucca, Nv 89445
Elko, Nv 89801 Subdivision Name: Canyon Run County: Humboldt

2. LOCATION NE1/4 SW1/4 1/4 Sec 18 T 35N N - R 38E E Latitude 40 54.472N UTM E NAD 27
PERMIT/WAIVER No. 0 Parcel No. 10-557-41 Longitude 117 44.940W N

3. WORKED PERFORMED Replace Recondition Deepen Other
4. PROPOSED USE Municipal/Industrial Irrigation Test Monitor Stock
5. WELL TYPE Cable Air Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam top soil		0	5	5
Med gravel clay & sand		5	10	5
Sand, small gravel & cobbles		10	80	70
Sand, med gravel & cobbles		80	220	140
Sand small gravel & clay		220	280	60
		280		-280

9. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280
HOLE DIAMETER (BIT SIZE)
10 7/8 Inches From 0 Feet To 280 Feet
 Inches From Feet Feet
 Inches From Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.376	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	280

Perforations:
Type of perforation PVC Screen
Size of perforation 1/16
From 220 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes
Neat Cement to Pumped Poured
Cement Grout 4 to 53 Pumped Poured
Concrete Grout to Pumped Poured
≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 55 to 280 Pumped Poured
Type: 3/8 minus
Bentonite Chips: Yes No 53 to 55 Pumped Poured
Type: 3/8 baroid

Date started: 7/15/2008
Date completed: 7/18/2008

7. Water Level
Static water level: 245.75 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: good

8. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15	30	4		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name High Desert Drilling LLC
Contractor
Address 4225 E Mary Way
Contractor
Winnemucca Nevada 89445
Nevada contractor's license number 62237
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site office 2140 & 2364
Signed [Signature] 2364
By driller performing actual drilling or contractor
Date _____

USE ADDITIONAL SHEETS IF NECESSARY

N 40.907978
W 117.748032 NAD27