STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 100602
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62663

1. OWNER Clint & Sasha Altman
MAILING ADDRESS 8655 Herschell Road

ADDRESS AT WELL LOCATION 8655 Herschell Road
Winnemucca, NV 89445
Subdivision Name: County: Pershing

2. LOCATION SW¼NW¼ Sec33T34N/ R37E
PERMIT/WAIVER NO. 009-210-14
Issued by Water Resources Parcel. No.

Latitude N40°78013 UTM E ☐ NAD 27
Longitude W117°83315 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		305	310	5
Gravel		310	340	30
rock ledge		340	350	10
cobles/gravel/sand	X	350	390	40
hard rock		390	425	35

2008 AUG 28 AM 11:00
STATE ENGINEER AND WATER

Deepening of log 25945

N40.780225
W117.832185 NAD27

Date started: August 20, 20 08
Date completed: August 21, 20 08

7. Water Level
Static water level: 146 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		4

9. WELL CONSTRUCTION
Depth Drilled 425 Feet Depth Cased 425 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	305 Feet	425 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9	1.88	305	425

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32x4
From 365 feet to 425 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc.
By driller performing actual drilling on site or contractor
Date August 26, 2008

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com