STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106680
Permit No.
Basin 1890

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 62835

1. OWNER GEOFFRY GOLDSBOROUGH
MAILING ADDRESS P, O. BOX 111
MONTELLO, NV 89830

ADDRESS AT WELL LOCATION 1.5 MILES E. OF MONTELLO, NV
Subdivision Name: GAMBLE DISTRICT County: ELKO

2. LOCATION SW ¼ NE ¼ Sec 21 T 39N N/S R 69 E
PERMIT/WAIVER No. 010-58M-009
Issued by Water Resources Parcel No.

Latitude 41.252374 NAD27
Longitude 114.166594
UTM E 11T 0737385 [X] NAD 27
N 4570433 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSOIL (SANDY) | | 0 | 1 | 1 |
| BROWN SAND | | 1 | 10 | 9 |
| TAN SAND/GRAVEL | | 10 | 20 | 10 |
| FINE GRAVEL & SAND | | 20 | 50 | 30 |
| COARSE GRAVEL | XXX | 50 | 120 | 70 |
| | | | | |
| FIRST WATER 60' | X | | | |
| SECOND WATER 100' | XXX | | | |

2008 AUG 22 PM 12:00 STATE ENGINEER

Date started: 15-Aug, 20 08
Date completed: 15-Aug, 20 08

7. Water Level
*Static water level:* 38 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 70 | 2.5 | |

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 120 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +2 | 20 |
| 6 5/8 | | SDR 21 | 20 | 120 |
| | | | | |

Perforations:
Type of perforation FACTORY SCREEN PVC
Size of perforation 1/0/1900
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 2 to 20 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 120 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 20 to 50 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS - TREMIED IN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed Jerry C. Bauer (By driller performing actual drilling on site or contractor)
Date 8/18/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY