WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106706
Permit No.
Basin 070

NOTICE OF INTENT NO. 59144

1. OWNER Model T. Casino
MAILING ADDRESS 1130 W. Winnemucca Blvd, Winnemucca NV
ADDRESS AT WELL LOCATION Model T Casino 1130 W. Winnemucca Blvd, Winnemucca NV.

2. LOCATION ~~SE~~ NW ¼ ~~SW~~ SE ¼ Sec. 30 T. 36 N/S R. 38 E. Humboldt County
PERMIT NO. Fac. #5-000114 (Issued by Water Resources) 015-282-09 (Parcel No.) Waiver # R-583 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	2"	2"
Road base sand + gravel		2"	1'	10"
Silty Sand		1'	7½'	6½'
Clayey silty sand		7½'	14'	6½'
Gravelly sand	17½'	14'	23½'	9½'
NAD 83				
Easting 2856345.17				
Northing 15387319.16				
Waiver # R-583				
~~40.964708~~				
PRW-3				

Date started 5-19-08, 20
Date complated 5-19-08, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23½ Feet Depth Cased 23½ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
16"	0	23½'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		Sch. 40		
			0'	3½'

Perforations:
Type perforation Factory Slot
Size perforation .050
From 3½ feet to 23½ feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6"
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
3'-6" Bentonite
Gravel Packed: ☒ Yes ☐ No
From 23½' feet to 3' feet

9. WATER LEVEL
Static water level 19½ feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 65°F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address P.O. Box 940 (Contractor)
Meridian ID. 83642
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed Mike Cam (By driller performing actual drilling on site or contractor)
Date 5-23-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627