

106708

Log No. _____
Permit No. _____
Basin Ø70

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59144

1. OWNER Model T Casino ADDRESS AT WELL LOCATION Model T Casino
MAILING ADDRESS 1130 W. Winnemucca Blvd. Winnemucca Nv. 1130 W. Winnemucca Blvd. Winnemucca Nv.
2. LOCATION SENE 1/4 SW 30 T. 36 Ø/S.R. 38 E. Humboldt County
PERMIT NO. Fact # 5-00014 015-282-09 Waiver # R-583
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	2'	2"
Road base mix		2"	1 1/2'	16"
Silty sand		1 1/2'	7 1/2'	6'
Clayey silty sand		7 1/2'	12 1/2'	5'
gravelly sand-tan	17'	12 1/2'	25'	12 1/2'
NAD 83				
Easting 2856246.93				
Northing 15387279.46				
Waiver # R-583				
N40.964602				
W 117.743804 NAD83				
PRD				
DPE-65				

8. WELL CONSTRUCTION
Depth Drilled 25' Feet Depth Cased 25' Feet

HOLE DIAMETER (BIT SIZE)
From 16" To 25'
Inches 0 Feet 25'
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>Sch. 40</u>	<u>0</u>	<u>5'</u>

Perforations:
Type perforation Factory slot
Size perforation Ø50
From 5' feet to 25' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 1'
 Neat Cement
Placement Method: Pumped Poured 4 1/2 - 1' Bentonite
 Cement Grout
 Concrete Grout

Gravel Packed: Yes No 4 1/2'
From 25' feet to _____ feet

9. WATER LEVEL
Static water level 17' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 85° °F Quality _____

Date started 5-20-08, 20 _____
Date completed 5-20-08, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>24-21</u>	<u>11.9</u>	<u>11:12-12:42</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling Inc. Contractor
Address P.O. Box 940 Contractor
Meridian ID 83642
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed Mike C
By driller performing actual drilling on site or contractor
Date 5-23-08