STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106848
Permit No. [redacted]
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33535

1. OWNER Trident Trust LP, Partnership Downer Family
MAILING ADDRESS 30240 Rancho Viejo #B
San Juan Capistrano CA. 92675
ADDRESS AT WELL LOCATION 1255 So Lamb Blvd.
Las Vegas, NV.
Subdivision Name: County: Clark

2. LOCATION NW¼ NW¼ Sec 05 T 21 N/S R 62 E
PERMIT/WAIVER No. 161-05-110-003
Issued by Water Resources Parcel No.
Latitude N.36° 09' 28.5" UTM E NAD 27
Longitude W115° 04' 51.7" N NAD 83/WGS 84
Well # MW-20

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other 8" H.S. Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Asphalt/Concrete Base		0	1	1
Sandy Silt		1	10	9
Sand w/silt		10	12	2
Sandy Clay		12	15	3
Silty Sand	X	15	25	10
Silty Clay		25	35	10
Sand w/silt, gravel	X	35	40	5
Sandy Clay		40	60	20

RECEIVED
SEP 08 2008
LAS VEGAS OFFICE

Date started: 8-7, 20 08
Date completed: 8-7, 20 08

7. Water Level
Static water level: 14.3' ± 30' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N.A.	

9. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40	ASTM F480	0	20
2"	Sch. 40	ASTM F-48	0	40
	Nested Well			

Perforations:
Type of perforation Factory Slots
Size of perforation .020"
From 10 feet to 20 feet
From 35 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[X] Concrete Grout 0 to 8 [ ] Pumped [X] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 9 to 20 [ ] Pumped [X] Poured
Type: #3 Montery Sand & 34-40
Bentonite Chips: [X] Yes [ ] No 8 to 9 [ ] Pumped [X] Poured
Type: 3/8 Bentonite Hole Plug & 20-34

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elite Drilling Inc.
Address (Contractor) 4255 W. Post Rd.
Las Vegas NV 89118
Nevada contractor's license number issued by the State Contractor's Board 54931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1944
Signed Thomas N. Beall
By driller performing actual drilling on-site or contractor
Date 9-4-08

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)
(O) 627