

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. **106851**  
Permit No. \_\_\_\_\_  
Basin **212**

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Trident Trust LP Partnership Dowener Family ADDRESS AT WELL LOCATION 4235 E. Charleston Blvd  
MAILING ADDRESS 30240 Rancho Viejo #3 Las Vegas, NV  
San Juan Capistrano CA 92675 Subdivision Name: \_\_\_\_\_ County: Clark

NOTICE OF INTENT NO. 33534

2. LOCATION NW 1/4 NW 1/4 Sec 05 T 21 N R 62 E Latitude N36°09'31.3" UTM E  NAD 27  
PERMIT/WAIVER No. 161-05-110-002 Longitude W 115°04'55.4" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. MW-15

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other 8" H.S. Auger

5. WELL TYPE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>2" Asphalt Base</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>Clayey Sand</u>		<u>1</u>	<u>5</u>	<u>4</u>
<u>Silty Clay</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>Sandy Clay</u>		<u>10</u>	<u>12</u>	<u>2</u>
<u>Silty Sand</u>	<u>X</u>	<u>12</u>	<u>14</u>	<u>2</u>
<u>Sandy Clay</u>		<u>14</u>	<u>20</u>	<u>6</u>
<u>Silty Sand w/ clay</u>	<u>X</u>	<u>20</u>	<u>21</u>	<u>1</u>
<u>Silty Clay</u>		<u>21</u>	<u>25</u>	<u>4</u>

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
<u>25</u>		<u>25</u>	

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>8</u>	<u>0</u>	<u>25</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2" sch 40</u>	<u>F-480</u>	<u>PVC</u>	<u>0</u>	<u>25</u>

Perforations:  
Type of perforation Factory Slots  
Size of perforation 020  
From 10 feet to 25 feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 8  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 9 to 25  Pumped  Poured  
Type: #3 Monterey Sand  
Bentonite Chips:  Yes  No 8 to 9  Pumped  Poured  
Type: 3/8 Bentonite Hole Plug

DCARD/DWP RECEIVED  
SEP 08 2008  
LAS VEGAS OFFICE

7. Water Level  
Static water level: 12.89 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc Contractor  
Address 4255 W. Post Rd. Contractor  
Las Vegas, Nevada 89118  
Nevada contractor's license number 54931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources the on-site driller M-1944

Signed Thomas M. Beall  
By driller performing actual drilling on-site or contractor  
Date \_\_\_\_\_

USE ADDITIONAL SHEETS IF NECESSARY