

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. **106855**  
Permit No. \_\_\_\_\_  
Basin **212**

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Trident Trust LP Partnership** ADDRESS AT WELL LOCATION **4235 E. Charleston Blvd**  
MAILING ADDRESS **30240 Rancho V. Circle #B Las Vegas Nevada**  
**San Juan Capistrano CA 92675** Subdivision Name: \_\_\_\_\_ County: **Clark**  
2. LOCATION **NW 1/4 NW 1/4 Sec 05 T 21 N R 62 E** Latitude **36°09'30.3"** UTM E  NAD 27  
PERMIT/WAIVER No. **161-05-110-002** Longitude **115°04'55.1"** N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. **MW-14**

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Other **6" HS Auger**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>2" Asphalt Base</b>		<b>0</b>	<b>1</b>	<b>1</b>
<b>FINE SILTY SAND</b>		<b>1</b>	<b>5</b>	<b>4</b>
<b>SILTY CLAY</b>		<b>5</b>	<b>10</b>	<b>5</b>
<b>SANDY SILTY CLAY</b>		<b>10</b>	<b>12</b>	<b>2</b>
<b>SILTY CLAY</b>		<b>12</b>	<b>14</b>	<b>2</b>
<b>SILTY SAND</b>	<b>X</b>	<b>14</b>	<b>17</b>	<b>3</b>
<b>SILTY CLAY</b>		<b>17</b>	<b>25</b>	<b>8</b>

9. WELL CONSTRUCTION

Depth Drilled **25** Feet Depth Cased **25** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<b>8</b>	<b>0</b>	<b>25</b>	<b>25</b>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>2" sch 40</b>	<b>F-480</b>	<b>P4L</b>	<b>0</b>	<b>25</b>

Perforations:

Type of perforation **Factory Slots**  
Size of perforation **020**

From **10** feet to **25** feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout **0** to **8**  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No **9** to **25**  Pumped  Poured  
Type: **#3 Monterey Sand**

Bentonite Chips:  Yes  No **15** to **9**  Pumped  Poured  
Type: **3/8 Bentonite Hole Plug**

Date started: **8-11-08**  
Date completed: **8-11-08**

7. Water Level  
Static water level: **14.29** feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<b>NA</b>	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Elite Drilling Inc.** Contractor  
Address **4255 W. Post Rd.** Contractor  
**Las Vegas, Nevada**  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board **54931**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M-1944**

Signed **Thomas M. Beall**  
By driller performing actual drilling on-site or contractor  
Date **9-4-08**