

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. **106857**  
Permit No. \_\_\_\_\_  
Basin **212**

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **33533**

1. OWNER **Trident Trust LP Partnership** ADDRESS AT WELL LOCATION **4235 E. Charleston Blvd**  
MAILING ADDRESS **30240 Rancho Vejo Rd #8 Las Vegas, Nevada**  
**San Juan Capistrano CA 92625** Subdivision Name: \_\_\_\_\_ County: **Clark**

2. LOCATION **NW 1/4 NW 1/4 Sec 05 T 21 N R 62 E** Latitude **N 36° 09' 30.8"** UTM E  NAD 27  
PERMIT/WAIVER No. **161-05-110-002** Longitude **W 115° 04' 55.5"** N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. **VE-2**

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Other **10" HSA**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>2" Asphalt Base</b>		<b>0</b>	<b>1</b>	<b>1</b>
<b>SILTY SAND WITH</b>		<b>1</b>	<b>3</b>	<b>2</b>
<b>SILTY CLAY</b>		<b>3</b>	<b>4</b>	<b>1</b>
<b>CLAYEY SILT</b>		<b>4</b>	<b>12</b>	<b>8</b>

9. WELL CONSTRUCTION  
Depth Drilled **12** Feet Depth Cased **12** Feet  
HOLE DIAMETER (BIT SIZE)  
From **0** To **12**  
**10** Inches **0** Feet **12** Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>4"</b>	<b>Sch 40</b>	<b>F400 PVC</b>	<b>0</b>	<b>12</b>

Perforations:  
Type of perforation **Factory Slots**  
Size of perforation **.820**  
From **7** feet to **12** feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  No  
 Neat Cement to  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout **0** to **5**  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No **6** to **12**  Pumped  Poured  
Type: **#3 Monterey Sand**  
Bentonite Chips:  Yes  No **5** to **6**  Pumped  Poured  
Type: **3/8 Bentonite Hole Plug**

Date started: **8-11** 20 **08**  
Date completed: **8-11** 20 **08**

7. Water Level  
Static water level: **NO Water** feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>NA</b>			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **Elite Drilling Inc.** Contractor  
Address **4255 W. Post Rd.** Contractor  
**Las Vegas, Nevada 89118**  
Nevada contractor's license number **54931**  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M-1944**  
Signed **Thomas M. Beall**  
By driller performing actual drilling on-site or contractor  
Date **9-4-08**