

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. **106876**
Permit No. **212**
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33806

1 OWNER Clark County Aviation
MAILING ADDRESS P. O. Box 11005, Las Vegas, NV

ADDRESS AT WELL LOCATION McCarren Airport Terminal 3
5757 Wayne Newton blvd, Las Vegas, NV

Subdivision Name: County: Clark

2 LOCATION NE ¼ NE ¼ Sec 34 T 21S N/S R 61 E
PERMIT/WAIVER No. DW 1243A 162-34-502-010
Issued by Water Resources Parcel No.

Latitude 632011 UTM E NAD 27
Longitude 486855.2 N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
If yes, what is replacement well NOI?

Is there an existing well log? yes
If yes, what is NDWR well log #? 103517

4 EXISTING WELL CONSTRUCTION
Depth Drilled 51 Feet Depth Cased 50 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: Casing was removed

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	20

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Machine Slot
From 20 feet to 50 feet	0.032

Additional Perforations:

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot
	From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level 28' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	
From 20 feet to 35 feet			Cement Grout	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From	feet to	feet		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

6 Additional Notes or Comments
Existing grade was 15' below original grade, pulled well casing, and vacuum well pack to -35 below original grade, (20' below existing grade) and poured cement to 5' from the surface.

Location # 7410

Neat Cement Fluid Weight lbs/gal
Bentonite Grout % bentonite
Date Started 8-20-08
Date Completed 8-20-08

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Griffin Dewatering Corp.
Contractor

Address 536 E. Maitland St.
Contractor

Ontario, CA 91761

Nevada contractor's license number issued by the State Contractor's Board C-23 0031246

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 9-12-08

