STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106952
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62656

1. OWNER Jay & Cory Nyborg
MAILING ADDRESS 3270 E. Thomas Canyon Rd

ADDRESS AT WELL LOCATION 3270 E. Thomas Canyon Rd
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION NW¼NE¼ Sec13T35N/ R37E
PERMIT/WAIVER NO. 013-541-02
Issued by Water Resources Parcel. No.

Latitude N40°91494 UTM E ☐ NAD 27
Longitude W117°76458 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		100	105	5
Cobles/gravel		105	115	10
Clay w/gravel	X	115	120	5
Cobles/gravel		120	160	40
sand/gravel	X	160	197	37

N40.915036
W 117.763617 NAD27

RECEIVED 2008 JUN 30 PM 12:39 STATE ENGINEERS OFFICE

Date started: June 19, 20 08
Date completed: June 20, 20 08

7. Water Level
Static water level: 97 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		8

9. WELL CONSTRUCTION
Depth Drilled 197 ~~200~~ Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	100 Feet	197 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	188	97	197

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32x4
From 157 feet to 197 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement Existing to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc.
By driller performing actual drilling on site or contractor
6-24-08

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com