

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 106958
 Permit No. _____
 Basin φ71

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **62657**

1. OWNER **Harlin Knight** ADDRESS AT WELL LOCATION **6295 Mills Road**
 MAILING ADDRESS **6295 Mills Road Winnemucca, NV** **Winnemucca, NV 89445**
 SE
 Subdivision Name: _____ County: **Humboldt**

2. LOCATION **SE 1/4 Sec 12 T35N R37E** Latitude **N40°9'18.52"** UTM E _____ NAD 27
 PERMIT/WAIVER NO. _____ 013-513-01 Longitude **W117°7'60.45"** N _____ NAD 83/WGS 84
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Coble/gravel		3	50	47
Gravel		50	80	30
Clay		80	90	10
Sand/gravel	X	90	100	10
Clay		100	130	30
Course gravel/Sand	X	130	197	67

9. WELL CONSTRUCTION

Depth Drilled **197** Feet Depth Cased **197** Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 1/4 Inches	0 Feet 20 Feet
11 Inches	20 Feet 197 Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	17
6.625	4	.316	17	197

Perforations:

Type of perforation **Factory Cut**
 Size of perforation **050**

From	To
157 feet to	197 feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Annular Seal: Yes No

Material	From	To	Method
<input checked="" type="checkbox"/> Neat Cement	0	50	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	50	197	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
Bentonite Chips: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

7. Water Level

Static water level: **100** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Draw Down (Feet Below Static)		
G.P.M.	20	102	18
Time (Hours)			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
 Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**

Signed *Fred Anderson*
 By driller performing actual drilling on site or contractor
 Date **June 24, 2008**

RECEIVED
 2008 JUN 30 PM 12:39
 STATE ENGINEERS OFFICE

N 40.914617
 W 117.759487 NAD27