STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106973
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60659

1. OWNER ROB GOINGS
MAILING ADDRESS 1175 DODGION LANE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1125 DODGION LANE
FALLON, NV 89406
Subdivision Name: County: CHURCHILL

2. LOCATION NW ¼ SW ¼ Sec 5 T 18S N/S R 29 E
PERMIT/WAIVER No. 010-171-04
Issued by Water Resources Parcel No.

Latitude [redacted] UTM E 348537 ☒ NAD 27
Longitude [redacted] N 4368278 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	18	8
BROWN SANDS		18	25	7
GREY CLAY		25	28	3
GREY SANDS		28	39	11
GREY CLAY		39	45	6
GREY SANDS		45	70	25
BLACK SILY/CLAYS		70	90	20
GREY CLAY		90	110	20
BROWN SILTY SANDS		110	115	5
BROWN NDS	X	115	132	17
WELL CORRECTED TO STATE SPECS				
N 39.452637				
W 119.760334 NAD27				

Date started: 28-Jan, 20 08
Date completed: 2/5/2008, 20 08

9. WELL CONSTRUCTION
Depth Drilled 132 Feet Depth Cased 132 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	132	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	132

Perforations:
Type of perforation MACHINE SLOT
Size of perforation 0.08
From 126 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 1 to 10 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 11 to 50 ☒ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 15' 7" feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOL °F
Quality: UNTESTED

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the *State Contractor's Board* 11752
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2199
Signed (By driller performing actual drilling on site or contractor)
Date 28-Feb-08

Rev. 05-08

USE ADDITIONAL SHEETS IF NECESSARY