STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106976
Permit No.
Basin 110B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61613

1. OWNER Walker Lake GID
MAILING ADDRESS 175 Wassuk Way
Walker Lake, NV 89415

ADDRESS AT WELL LOCATION Walker Lake
Subdivision Name: County: Mineral

2. LOCATION SE ¼ SE ¼ Sec 8 T 09N N/S R 29 E
PERMIT/WAIVER No. ~~26039, 26714, 53023 & 53024 Permits~~
Issued by Water Resources Non-Res Parcel No.

Latitude 38.64973
Longitude W118.75982
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles		0	22	22
Cobbles & Some Clay		22	500	478
This hole did not show enough water. Abandoned bottom 400 ft with bentonite (gopher grout) and the top 100' with cement.				

2008 SEP 1 P 12:56 STATE ENGINEER UTAH

N 38.649810
W118.758847 NAD27

Date started: 21-Jul, 20 08
Date completed: 31-Jul, 20 08

7. Water Level
Static water level: ~~N/A~~ 24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		N/A

9. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	500	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
N/A		N/A		

Perforations:
Type of perforation N/A
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 100 ☒ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada Inc dba Humboldt Drilling & Pump Co (Contractor)
Address 4975 W Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed Cheryle Jaynes (By driller performing actual drilling on site or contractor)
Date 8/26/2005

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY