STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106977
Permit No.
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61830

1. OWNER HINKLEY RESIDENTS
MAILING ADDRESS 13090 SEMINOLE DR
SE STAGECOACH, NV 89429

ADDRESS AT WELL LOCATION 13035 SENECA DR
STAGECOACH, NV 89429
Subdivision Name: County: Lyon

2. LOCATION ¼ ¼ Sec 12 T 17N N/S R 22 E
PERMIT/WAIVER No. SE 15-324-04
issued by Water Resources Parcel No.

Latitude 39.34928°N
Longitude 119.45334°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLES		0	5	5
VOLCANIS GRAVELS		5	63	58
BROWN CLAY AND GRAVELS		63	172	109
BROWN CLAY		172	213	41
VOLCANI GRTAVELS	X	213	260	47
VERY BROKES GRAVELS	XXX	260	280	20

N 39.349365
W 119.453336 NAD27

Date started: 28-Jan , 20 28
Date completed: 06-Feb , 20 08

9. WELL CONSTRUCTION
Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
9 7/8	Inches	180	Feet	260	Feet
6 1/8	Inches	260	Feet	280	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	260
5	11.63	.188	250	260

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 240 feet to 260 feet
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 55 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 260 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 136 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed
By driller performing actual drilling on site or contractor
Date 02/15/2008

(Rev. 05-03)

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEER'S OFFICE
2008 SEP -3 AM 11:20
RECEIVED

COPY