STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106982
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60461

1. OWNER KAREN COZETTE
MAILING ADDRESS P. O. BOX 809
FALLON, NV 89406

ADDRESS AT WELL LOCATION 3300 ALCORN
FALLON, NV 89406
Subdivision Name: County: CHURCHILL

2. LOCATION SW ¼ SE ¼ Sec 27 T 19N N/S R 28 E
PERMIT/WAIVER No. 008-431-20 Issued by Water Resources
Parcel No.
Latitude 39.479897 Longitude 118.823717
UTM E 343133. N 4370857
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SANDS		1	18	17
BROWN CLAY		18	20	2
BROWN SANDS		20	40	20
BROWN CLAY		40	46	6
GRAY SANDS		46	70	24
GRAY CLAY		70	74	4
BROWN SANDS		74	90	16
BROWN CLAY		90	93	3
GRAY SANDS		93	120	27
GRAY CLAY		120	130	10
GRAY SANDS, GRAVEL		130	180	50
GRAY CLAY		180	190	10
BROWN SANDS/GRAVEL	X	190	215	25

Date started: 9-28-07, 20
Date completed: 9-28-07, 20

9. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6	Inches	100	Feet	215	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	215

Perforations:
Type of perforation MACHINE SLOT
Size of perforation 0.08
From 209 feet to 213 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement 0 to 10 [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 10 to 100 [X] Pumped [ ] Poured
Gravel Pack: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 26 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COOL °F
Quality: UNTESTED

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	30		1 HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO DRILLING CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed By driller performing actual drilling on site or contractor
Date 15-Oct-07

(Rev. 05 06)

USE ADDITIONAL SHEETS IF NECESSARY