STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106985
Permit No.
Basin 082

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63205

1. OWNER Mr. Andrew Stuart
MAILING ADDRESS 750 Pilot Rd. Suite F
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION 2500 East Second St.
Reno, NV
Subdivision Name: Grand Sierra Resort County: Washoe

2. LOCATION SW ¼ SE ¼ Sec 7 T 19N N/S R 20 E
PERMIT/WAIVER No. FAC ID 4-00027 | 012-211-28
Issued by Water Resources Parcel No.

Latitude 39.522811
Longitude 119.776492
UTM E. ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt and fill material		0	2	2
Native, dark brown, g&boulders, s		2	21	19
Tan,grey,sandy,gravels, angular	x	21	42	21

N39.522900
W 119.775469 NAD27

RECEIVED 2008 AUG -8 AM 8:12 STATE ENGINEER'S OFFICE

Date started: 30-Jul, 20 08
Date completed: 7/30/2008, 20 08

9. WELL CONSTRUCTION
Depth Drilled 42 Feet Depth Cased 42 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7	Inches	0	Feet	42	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		schd 40	0	42

Perforations:
Type of perforation screen
Size of perforation 0.01
From 22 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement 0 to 17 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 20 to 42 ☐ Pumped ☒ Poured
Type: Monterey # 2/12
Bentonite Chips: ☒ Yes ☐ No 17 to 20 ☐ Pumped ☒ Poured
Type: 3/8" Hole Plug

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear
Contractor
Address 3894 Railroad Avenue
Contractor
Yuba City, CA 95991
Nevada contractor's license number issued by the *State Contractor's Board* 0021976
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2234
Signed
By driller performing actual drilling on site or contractor
Date 8/6/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY