Faxed to NW. 1st Corp. 10/24/00

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106986
Permit No.
Basin 069

NOTICE OF INTENT NO. No NOI

1. OWNER Paradise Valley Comm Board
MAILING ADDRESS P.O. Box 55
Paradise Valley NV 89426-0055

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 25 T. 42 N/S R. 39 E. Humboldt County
PERMIT NO. 63557 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil	No	0	12	12
Clay	No	12	15	3
Sand Gravel	Yes	15	90	75
Yellow Clay		90	112	22
Soft Sandy Clay		112	165	53
Yellow Clay		165	195	30
Small Gravel + Sand		195	260	65
Yellow Clay		260	271	11
Small Gravel + Sand		271	302	31
Yellow Clay		302	312	10
Small Gravel + Sand		312	336	24
Yellow Clay		336	340	4

RECEIVED 2000 AUG -6 AM 11:13 STATE ENGINEERS OFFICE

Date started Nov 10, 1999
Date completed Jan 15 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	55	2
60	107	2
75	133	2

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 5/8	0	340

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16	.188	0	340

Perforations:
Type perforation Factory Cut
Size perforation 1/8 x 3 8 Rows
From 240 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 FT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 150 feet to 340 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name L.B.J. Drilling Co. (Contractor)
Address P.O. Box 902 (Contractor)
Winnemucca NV 89446
Nevada contractor's license number issued by the State Contractor's Board 9605
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed [signature] (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627