COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106987
Permit No.
Basin 049

NOTICE OF INTENT NO. 55653

1. OWNER Burea of Land Management
MAILING ADDRESS 3900 East Idaho Street
Elko, NV 89801

ADDRESS AT WELL LOCATION I-80 - Hunter Exit

2. LOCATION SE ¼ NE ¼ Sec 7 T 33 N R 54 E Elko County

PERMIT NO. 71371 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	40	
Clay		40	45	
Hard rock		45	60	
Clay course sand				
with fractured rock		60	115	
Sandstone		115	120	
Broken fracture sandstone		180	185	
Hard sandstone		185	192	
Soft clay sandstone		192	200	
Hard sandstone		200	203	
Creamcolored clay		203	218	
Caliche		218	222	
Clay w/ cobbles		222	225	
Fractured rock		225	232	
Rock solid		232	247	
Fractured rock		247	248	
Hard rock		248	263	
Fractured rock		263	279	
Sandstone		279	282	

2008 AUG 22 AM 10:30 STATE ENGINEER'S OFFICE

Date started November 17, 20 05
Date completed November 23, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
600	unknown	8 hrs.

8. WELL CONSTRUCTION

Depth Drilled 282 Feet Depth Cased 282 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
13 3/4 Inches	0 Feet	282 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.250	+3	282

Perforations:
Type perforation Johnson stainless screen
Size perforation .060
From 177 feet to 197 feet
From 242 feet to 277 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 158' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 158 feet to 6 x 9 SRI rock, 282 feet

9. WATER LEVEL
Static water level 43.7 feet below land surface
Artesian flow no G.P.M N/A P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed Fred Anderson Drilling Inc.
By driller performing actual drilling on site or contractor
Date November 28, 2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com