WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106989
Permit No.
Basin 097

NOTICE OF INTENT NO. 55676

1. OWNER Vidler Water Company
MAILING ADDRESS 3480 GS Richards Blvd 101 Carson City, NV 89703
ADDRESS AT WELL LOCATION 00000 Rainbow Road

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 26 N/S R. 18 E. Washoe County
PERMIT NO. #3787 A King (Issued by Water Resources) | Parcel No. 7405103 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand Light Gray		0	5	
Sandy Clay Brown		5	27	
Silty Sand Fine to Med Brw		27	52	
Silty Sandy Clay Grn		52	62	
Silty Sand Fine to Coarse DK Green		62	71	
Clayey Sand Fine Sand DK Grn		71	75	
Sand Fine to Coarse DK Green		75	77	
Silty Sand w/ clay Fine Sd DK Green		77	85	
Silty sand fine to coarse DK Green		85	95	
Sand fine to coarse DK gray		95	97	
Clay Dark green		97	106	
Sand some Silt & Clay DK Gre		106	116	
Silty Sand DK Green		116	120	
Clayey Silt w/ sand DK Gre		120	123	
Sand - Coarse - Gray		123	130	
N 40.41201				
W 119.973314 NAD27				
GPS coords:				
Lat 40°06'39.98				
Long 119°58'45.66				
Datum: NAD83				

Date started 7/9, 2007
Date completed 8/15, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

GPM.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 121 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0 Feet	130 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	0.720	.02	91	121

Perforations:
Type perforation
Size perforation .02
From 0 feet to 91 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 89
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 89 feet to 120 feet

9. WATER LEVEL
Static water level 18.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Strata Exploration (Contractor)
Address PO Box 657 (Contractor)
Clarksburg, Ca 95612
Nevada contractor's license number issued by the State Contractor's Board C2300 34236A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1978
Signed (By driller performing actual drilling on site or contractor)
Date 08/16/07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627