CANV-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106990
Permit No.
Basin 097

NOTICE OF INTENT NO. 55678

1. OWNER Vidler Water Co
MAILING ADDRESS 3480 GS Richards Blvd Ste 101 Carson City, NV 89703
ADDRESS AT WELL LOCATION 00000 Rainbow Rd

2. LOCATION SE ~~SW~~ ¼ NW ¼ Sec. 20 T. 26 ~~N~~S R. 18 E. Washoe County
PERMIT NO. #3787A-ruling (Issued by Water Resources) | 7405103 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Playa Silt and Clay Gray		0	5	
Sand Med Lt gray Brown		5	16	
Clayey Silty Sand gray-Brn		16	24	
Sand Med to coarse Gray		24	44	
Clayey Silty Sand Gray		44	52	
Silty Sand Gray		52	53	
Clay Dark Green		53	65	
Clayey Silt Sand Dk gre		65	82	
Claystone Dk Blu-gr		82	147	
N 40.110743				
W 119.941558 NAD27				
GPS coords:				
Lat 40° 06 38 33 N				
Long 119° 59 33 34 W				
datum: NAD 83				

Date started 7/9/07, 2007
Date completed 08/15, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 147 Feet Depth Cased 81.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	147 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	0.720	2"	0	71.5

Perforations:
Type perforation
Size perforation .02
From 71.5 feet to 81.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 69.5
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 69.5 feet to 147 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Strata Exploration (Contractor)
Address PO Box 657 Clarksburg Ca 95612 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board C230034236A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 17-1978
Signed (By driller performing actual drilling on site or contractor)
Date 8/16/07

2008 SEP -2 PM 1:09

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627