STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106992
Permit No.
Basin 078

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61569

1. OWNER: C-PUNCH RANCH
MAILING ADDRESS: 1100 1/2 Fuss Road, Lovelock, NV 89419

ADDRESS AT WELL LOCATION: Granite Springs Valley

2. LOCATION SE ¼ NW ¼ Sec 11 T 26N N/S R 27 E
PERMIT/WAIVER No. _____ Issued by Water Resources _____ Parcel No.

Latitude ~~40.137~~ 40° 08.196N
Longitude ~~118.919~~ 118° 55.133W
UTM E _____ N _____
☐ NAD 27 ☒ NAD 83/WGS 84
Subdivision Name: _____ County: Pershing

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other.....

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other .....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface clay		0	10	10
Sandy clay		10	90	80
Clay		90	110	20
Sandy clay		110	140	30
Sand with clay layers		140	480	340
Clay with some sand		480	560	80

N 40.136711
W 118.917863 NAD27

2008 SEP -4 PM 12:54
STATE ENGINEER'S OFFICE

Date started 1-21-08, 20
Date completed 1/30/2008, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PWL=169	462	54	72

2008 FEB 19 PM 12:50

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 530 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
13 Inches	0 Feet	560 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	530

Perforations:
Type of perforation: mill slot
Size of perforation: .090x3

From 130	feet to	330	feet
From 370	feet to	390	feet
From 450	feet to	510	feet
From	feet to		feet
From	feet to		feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 530 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature 53 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HUMBOLDT DRILLING & PUMP COMPANY (Contractor)
Address 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed Judie Leach Office (By driller performing actual drilling on site or contractor)
Date 2/14/08

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY