

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 107033

Permit No. \_\_\_\_\_

Basin 087

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62023

1. OWNER Mr. Andrew Stuart  
MAILING ADDRESS 750 Pilot Road, Suite F  
Las Vegas, Nevada 89119

ADDRESS AT WELL LOCATION 2500 East 2nd Street  
Reno, NV. 89502  
Subdivision Name: Grand Sierra Resort County: Washoe

2. LOCATION NW ¼ SE ¼ Sec 7 T 19N N/S R 20 E  
PERMIT/WAIVER No. FAC ID - 4-00027  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39.524644 UTM E  NAD 27  
Longitude 119.777921 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other  Sonic

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Asphalt and fill material		0	2	2
Native, Brown, silts, boulders		2	12	10
Tan, silt, sand and gravels	x	12	35	23
<u>N39.524733</u>				
<u>W119.776948 NAD27</u>				

9. WELL CONSTRUCTION				
Depth Drilled	35	Feet	Depth Cased	35
HOLE DIAMETER (BIT SIZE)				
	From	To		
7	0	35	Inches	Feet
			Inches	Feet
			Inches	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		schd 40 pvc	0	35

Perforations:

Type of perforation	Size of perforation	From	To
pvc screen	0.01	10	35

Annular Seal:  Yes  No

<input checked="" type="checkbox"/> Neat Cement	0 to 5	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 8 to 35  Pumped  Poured

Type: Monterey # 2/12

Bentonite Chips:  Yes  No 5 to 8  Pumped  Poured

Type: 3/8" Hole Plug

Date started: 31-Jul, 2008  
Date completed: 31-Jul, 2008

7. Water Level  
Static water level: 14 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Boart Longyear  
Contractor  
Address 3894 Railroad Avenue  
Contractor  
Yuba City, CA 95991  
Nevada contractor's license number issued by the State Contractor's Board 0021976  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2234  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 8/6/2008