STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107045
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61732

1. OWNER Quadra-Robinson NV Mining V VD-08-06
MAILING ADDRESS P.O. Box 382
SE Ruth, NV 89319

ADDRESS AT WELL LOCATION Robinson Mine, 2 miles south of Ruth, NV
Subdivision Name: NA County: White Pine

2. LOCATION NW¼SE¼ Sec7T16N/ R62E
PERMIT/WAIVER NO. R-585 (Issued by Water Resources) NA (Parcel. No.)

Latitude 39.263187 Longitude 115.031520
UTM E 669832 N 4347621 ☒ NAD 27 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Limestone		0'	40'	40'
Cherty Limestone		40'	410'	370'
OTZ Monzanite		410'	620'	210'
Limestone		620'	760'	140'

Note:
PVC Plug Set @ 240'
Neat Cement placed inside PVC from 240' to surface.

Date started: 23-June, 20 08
Date completed: 24-June, 20 08

9. WELL CONSTRUCTION
Depth Drilled 760 Feet Depth Cased 740 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.750 Inches	0 Feet	18 Feet
6.750 Inches	18 Feet	760 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.96	.218	0	740

Perforations:
Type of perforation Slotted
Size of perforation .080
From 240 feet to 740 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 225' ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 230' to 760' ☐ Pumped ☒ Poured
Type: #6 SRI
Bentonite Chips: ☒ Yes ☐ No 225' to 230' ☒ Pumped ☐ Poured
Type: 3/8 Hole Plug

7. Water Level
Static water level: 422 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

RECEIVED 2008 JUL -8 AM 10:57 STATE ENGINEER'S OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Drilling Services (CONTRACTOR)
Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2283
Signed
By driller performing actual drilling on site or contractor
Date 01-Jul-08