STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107048
Permit No.
Basin Ø44

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62831

1. OWNER MARLIN D. PRUITT
MAILING ADDRESS 163 12TH STREET
NE ~~NW~~ ELKO, NV 89801

ADDRESS AT WELL LOCATION NE CORNER OF GOLDRUSH DRIVE & VAN BUREN AVE., RYNDON AREA 3233 Goldrush
Subdivision Name: Twin River Rancho #4 County: ELKO

2. LOCATION ~~NW~~ ¼ ~~NE~~ ¼ Sec 5 T 35N N/S R 57 E
PERMIT/WAIVER No. 026-006-005
Issued by Water Resources Parcel No.

Latitude 40.752280
Longitude 115.577591
UTM E 11T 0619718 [X] NAD 27
N 4534222 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	5	5
TAN CLAY & GRAVEL		5	120	115
GRAVEL	XXX	120	160	40

Date started: 22-Jul, 20 08
Date completed: 22-Jul, 20 08

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 157 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	17
6.625	SDR 17		17	157

Perforations:
Type of perforation PVC SLOTTED SCREEN
Size of perforation
From 137 feet to 157 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 157 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 15 to 50 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		1.5

STATE ENGINEER'S OFFICE
2008 JUL 25 AM 11:20
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed Dale C. Vedeen (By driller performing actual drilling on site or contractor)
Date 7/22/2008

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY