WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107054
Permit No.
Basin 105 Pg1

NOTICE OF INTENT NO. 60997 ~~63145~~

1. OWNER Heavenly valley
MAILING ADDRESS P O Box 2180 Stateline 89449 NV.
ADDRESS AT WELL LOCATION EAST peak LK

2. LOCATION SW ¼ SW ¼ Sec. 31 T 13 N/S R 19 E Douglas County
PERMIT NO. 76860T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation (snow making) ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blk/White Granite		360	367	7'
B/W Granite		367	381	14'
B/W Granite (Sm. Fracture)		381	382	1'
B/W Granite		382	386	4'
B/W Granite (Sm. Fracture)		386	387	1'
B/W Granite		387	389	2'
Tan clay/Granite Sand		389	393	4'
B/W Granite		393	407	14'
B/W Granite (Sm. Fracture)		407	427	20'
B/W Granite (Hard)		427	503	76'
B/W Granite (Soft)		503	504	1'
B/W Granite		504	608	104'
B/W Granite (Soft)		608	610	2'
B/W Granite		610	678	68'
B/W Granite (Soft)		678	680	2'
B/W Granite		680	698	18'
B/W Granite (Soft)		698	700	2'
B/W Granite		700	756	56'
B/W Granite (Soft)		756	758	2'
B/W Granite		758	865	107'
B/W Granite (Fract)		865	867	2'
B/W Granite (Hard)		867	948	81'
B/W Granite 950' Lg. Fracture		948	968	20'
B/W Granite		968	1010	42'

Date started 7/21/08, 2008
Date completed 8/17/08, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	400'	9 Hrs

8. WELL CONSTRUCTION
Depth Drilled 1010 Feet Depth Cased 427 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
18 Inches	0 Feet	105 Feet
12.25 Inches	105 Feet	427 Feet
6 Inches	427 Feet	1010 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	250	+2	105
10 3/4	28.04	250	+2	427

Perforations:
Type perforation Air
Size perforation 3/16 X 2
From 137 feet to 367 feet
From 377 feet to 387 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes, ☐ No
Depth of Seal 105
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 102' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 43° °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steves pumps & well Drilling (Contractor)
Address P O Box 249 Janesville CA 96114 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0071285
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2232
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/19/08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627