STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107057
Permit No.
Basin Ø89

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62090 ~~62089~~

1. OWNER Kelly Kitson
MAILING ADDRESS 4080 Bluewing Way
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 4080 Bluewing Way
Washoe Valley, NV 89704
Subdivision Name: County: Washoe

2. LOCATION SW ¼ SE ¼ Sec 32 T 17N N/S R 20 E
PERMIT/WAIVER No. 050-417-11 *Issued by Water Resources* Parcel No.

Latitude N39 17.455 Longitude W119 45.671
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G.		0	140	140
Gravel		140	150	10
D.G.		150	195	45
Rock		195	260	65
Sandy clay		260	275	15
D.G., Rock, Sandy clay		275	297	22
Sand stone		297	495	198
Total Depth 495 ft.				

N39.291022
W119.760182 NAD27

replaces original log# 9050 which was plugged under log# 111446
NOI# 62089

Date started: 19-Aug , 20 08
Date completed: 27-Aug , 20 08

9. WELL CONSTRUCTION
Depth Drilled 495 Feet Depth Cased 495 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
8 3/4	Inches	60	Feet	277	Feet
6 1/8	Inches	277	Feet	495	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	+1	297
5 9/16		188	279	495

Perforations:
Type of perforation Factory milled
Size of perforation 3 / 32 x 3

From 257	feet to	297	feet
From 340	feet to	391	feet
From 411	feet to	495	feet
From	feet to		feet
From	feet to		feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 55		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 297 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 137 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: Cool °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	220	1 hr
30+	495	4 hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, LLC *Contractor*
Address P.O. Box 60130 Reno, NV 89506 *Contractor*
Nevada contractor's license number issued by the *State Contractor's Board* 35387C
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 786
Signed *By driller performing actual drilling on site or contractor*
Date 9/15/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

MMH-F