


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



OFFICE USE ONLY  
Log No. 107084  
Permit No. \_\_\_\_\_  
Basin φ70

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60764

1. OWNER Draw Jenkins ADDRESS AT WELL LOCATION 6900 Airport Rd  
MAILING ADDRESS 6900 Airport Rd Winnemucca, Nv 89445  
Winnemucca, Nv 89445 Subdivision Name: \_\_\_\_\_ County: Humboldt  
2. LOCATION SE 1/4 Sec 9 T 35N N/S R 37E E Latitude 40 55.158N UTM E NAD 27  
PERMIT/WAIVER No. 0 13-075-09 Longitude 117 48.980W N

3. WORKED PERFORMED        
4. PROPOSED USE       
5. WELL TYPE Cable   RVC  
Deepen Other Recondition Municipal/Industrial Irrigation Monitor Test Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam top soil		0	1	1
Med gravel clay & sand		1	10	9
Sand, small gravel		10	50	40
Sand & gravel	X	50	160	110

9. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160  
HOLE DIAMETER (BIT SIZE)  
10 7/8 Inches From 0 Feet To 160 Feet  
         Inches From          Feet          Feet  
         Inches From          Feet          Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.375	STEEL	.168	0	20
6.900	PVC	sdr21= .450 in	20	160

Perforations:  
Type of perforation PVC Screen  
Size of perforation 1/16  
From 100 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  
Neat Cement \_\_\_\_\_ to \_\_\_\_\_ Pumped \_\_\_\_\_ Poured \_\_\_\_\_  
Cement Grout 4 to 60 Pumped  Poured \_\_\_\_\_  
Concrete Grout \_\_\_\_\_ to \_\_\_\_\_ Pumped \_\_\_\_\_ Poured \_\_\_\_\_  
≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_ Pumped \_\_\_\_\_ Poured \_\_\_\_\_  
Gravel Pack  Yes No 62 to 160 Pumped  Poured \_\_\_\_\_  
Type: 3/8 minus  
Bentonite Chips:  Yes No 60 to 62 Pumped  Poured \_\_\_\_\_  
Type: 3/8 baroid

Date started: 7/22/2008 20  
Date completed: 7/25/2008 20

7. Water Level  
Static water level: 48 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COLD °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	x
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
AIR	55	25	4	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name High Desert Drilling LLC  
Contractor  
Address 4225 E Mary Way  
Contractor  
Winnemucca Nevada 89445  
Nevada contractor's license number 62237  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources (the on-site driller) 2140  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

USE ADDITIONAL SHEETS IF NECESSARY

N 40.919412  
W 117.815363 NAD 27