STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 107092

Permit No.

Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62689

1. OWNER Don Fiori

MAILING ADDRESS 4275 Mayberry Drive, Reno, NV 89519

ADDRESS AT WELL LOCATION 8960 Pioneer Rd, Fallon, NV 89406

Subdivision Name: County: Churchill

2. LOCATION SW¼SW¼ Sec14T19N/ R27E

PERMIT/WAIVER NO. 007-151-26 (Issued by Water Resources; Parcel. No.)

Latitude 39.50416N | UTM E ☐ NAD 27

Longitude 118.92985W | N ☒ NAD 83/WGS 84

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Brown Clay		4	18	14
Brown Sand		18	22	4
Brown Clay		22	36	14
Brown Sand		36	42	6
Gray Sand		42	51	9
Gray Clay		51	58	7
brown Sand		58	74	16
Gray Sand		74	86	12
Brown Sand	X	86	108	22

N39.504244
W 118.928859 NAD27

Date started: 09/26, 20 2008

Date completed: 09/26, 20 2008

7. Water Level

Static water level: 18 feet below land surface

Artesian Flow: G.P.M. P.S.I

Water Temperature: cool °F

Quality: unknown

8. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

2008 OCT 14 PM 1:12

9. WELL CONSTRUCTION

Depth Drilled 108 Feet Depth Cased 108 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 Inches	0 Feet	108 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	14.96	.188	0	17
8	8.76	.508	~~0~~ 17	108

Perforations:

Type of perforation Saw Cut

Size of perforation 1/8

From 103 feet to 108 feet

From feet to feet

From feet to feet

From feet to feet

From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 10	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	10 to 100	☒ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 108 ☐ Pumped ☒ Poured

Type: 3/8

Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured

Type:

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (CONTRACTOR)

Address P.O. Box 1265 (CONTRACTOR)

Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2307

Signed

By driller performing actual drilling on site or contractor

Date 10/3/2008

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com