STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 107093

Permit No.

Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62688

1. OWNER Hawk Properties
MAILING ADDRESS 880 highway 95A
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1584 Meadowlark
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION SW¼NE¼ Sec21T19N/ R28E
PERMIT/WAIVER NO. 008-283-42
Issued by Water Resources Parcel. No.

Latitude 39.49829N UTM E ☐ NAD 27
Longitude 118.84525W N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	18	6
Brown Sand		18	30	12
Gray Clay		30	36	6
Fine gray Sand		36	48	12
Black Clay		48	55	7
Gray Sand		55	67	12
Brown Clay		67	71	4
Brown Sand	X	71	79	8

N39.498373
W 118.844262 NAD27

Date started: 10/3/ , 20 08
Date completed: 10/3 , 20 08

7. Water Level
Static water level: 18 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: cool °F
Quality: unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		1

2008 OCT 14 PM 1:12

9. WELL CONSTRUCTION
Depth Drilled 79 Feet Depth Cased 79 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	50 Feet
10 Inches	50 Feet	79 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	19
6 PVC	4.07	.316	19	79

Perforations:
Type of perforation Saw Cut
Size of perforation 1/8
From 74 feet to 78 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 10	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	10	to 50	☒ Pumped	☐ Poured
Gravel Pack: ☒ Yes ☐ No	50	to 79	☐ Pumped	☒ Poured
Type: 3/8				
Bentonite Chips: ☐ Yes ☒ No		to	☐ Pumped	☐ Poured
Type:				

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed
By driller performing actual drilling on site or contractor
Date 10/9/08