STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107110
Permit No.
Basin 871

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62887 ~~34776~~

1. OWNER George Peacher
MAILING ADDRESS P.O. Box 1726
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION 8865 Grass Valley Rd
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ SE ¼ Sec 24 T 35N N/S R 37 E
PERMIT/WAIVER No. 014-103-14 *Issued by Water Resources* Parcel No.

Latitude 40.888918 Longitude 117.762251
UTM E 435784 N 4526494 ☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravel, Cobbles		0	25	25
Gravel with Clay		25	45	20
Gravel and Cobbles	X	45	199	154

Date started: 12-Aug, 20 08
Date completed: 15-Aug, 20 08

9. WELL CONSTRUCTION
Depth Drilled 199 Feet Depth Cased 199 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.625	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.94	.188	+2	19
6.625	4.185	.316	19	199

Perforations:
Type of perforation Horizontal saw cut
Size of perforation 1/4" x 4"
From 159 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 3 to 104 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 104 to 199 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 128 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service (Contractor)
Address 3040 Callahan St (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-4-08

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY