STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107121
Permit No.
Basin 085

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62804

1. OWNER Daniel & Margaret Clancey
MAILING ADDRESS 775 Encanto Ct.
Sparks NV. 89441

ADDRESS AT WELL LOCATION 775 Encanto Ct
Sparks
Subdivision Name: County: Washoe

2. LOCATION SW¼SE¼ Sec9T21N/ R21E
Latitude 39.69512 UTM E ☐ NAD 27
Longitude 119.62808 N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. 076-300-17
Issued by Water Resources Parcel. No.

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black volcanic rock		715	735	20
Fracture	x	735	740	5
Black & brown volcanic rock		740	760	20
Brown volcanic rock		760	765	5
Black & brown volcanic rock		765	802	37

Washoe Pernit WL080108

N39.695210
W 119.627062 NAD27

Deepening of log # 20342

Date started: 9/22, 20 08
Date completed: 9/24, 20 08

9. WELL CONSTRUCTION

Depth Drilled 802 Feet Depth Cased 802 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	715 Feet	802 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.97	.188	682	802

Perforations:
Type of perforation Factory
Size of perforation 3/32 x 3
From 722 feet to 742 feet
From 782 feet to 802 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 474 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality: Not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+		3

2008 OCT -1 AM 11:15

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 9/29/08

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com