

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin **049**

NOTICE OF INTENT NO. **60110**

1. OWNER **FRANCISCO PATINO** ADDRESS AT WELL LOCATION **none established**
 MAILING ADDRESS **5298 VICTORY Rd**
ELKO, NV 89801 **33rd street**

2. LOCATION **NE 1/4 NE 1/4 Sec. 31 T. 34 N. R. 55 E. ELKO** County
 PERMIT NO. **N/A** Issued by Water Resources **064-001-014** Parcel No. **MEADOW VALLEY RANCHOS, UNIT #9** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	1	1
Clay, sand, gravel		1	18	17
Sand & gravel	<i>ru</i>	18	30	12
clay, sand, gravel		30	81	51
Coarse gravel	<i>ru</i>	81	82	1
clay, sand, gravel		82	101	19
Sandy clay		101	120	9
Sand & gravel	<i>ru</i>	120	128	8
Clay		128	130	2

G.P.S.:
40.79510 N
115.81462 W NAD83

Delay of completion due to emergency surgery

8. WELL CONSTRUCTION
 Depth Drilled **130** Feet Depth Cased **131** Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 50 Feet
8 Inches	50 Feet 130 Feet
6 Inches	120 Feet 130 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	12.92	.188	+1	130

Perforations:
 Type perforation **TORCH CUT**
 Size perforation **1/8 x 4**

From _____ feet to _____ feet
 From **80** feet to **130** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50 ft**
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Bentonite

Gravel Packed: Yes No
 From **50** feet to **130** feet

Date started **3/27**, 20**08**
 Date completed **5-08**, 20**08**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level **17** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **excellent**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **MUTH DRILLING CO** Contractor
 Address **203 PINE ST., ELKO, NV 89801** Contractor

Nevada contractor's license number issued by the State Contractor's Board **10819**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **632**

Signed **James Y Muth**
 By driller performing actual drilling on site or contractor
 Date **5-8-08**