

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY 107131

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin Ø47

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62208

1. OWNER JOSEPH C. CUMMING  
MAILING ADDRESS HC 30, BOX 330  
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION - 2 MILES EAST OF SR 228

Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SE ¼ SE ¼ Sec 14 T 30N N/S R 56 E Latitude 40.476558 UTM E 11T 0616575  NAD 87  
PERMIT/WAIVER No. 75523 006-270-001 Longitude 115.624758 N 4481350  NAD 83/WGS 84

issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other TEST HOLE

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	2	2
GRAVEL & ROCKS		2	7	5
CLAY & GRAVEL		7	80	73
CLAY & GRAVEL	X	80	180	100
GRAVEL w/ CLAY		180	240	60
CLAY & GRAVEL		240	280	40
GRAVEL w/ LITTLE CLAY		280	400	120
A LITTLE WATER FROM 280' TO 300'				
BASICALLY THIS IS A DRY HOLE				
WE PLUGGED THE HOLE & WILL TURN IN A HOLE PLUGGING REPORT				

9. WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To		
<u>7 7/8</u> Inches	<u>0</u> Feet	<u>400</u> Feet		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
N/A				
HOLE WAS PLUGGED				

Perforations:

Type of perforation N/A  
Size of perforation N/A

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: N/A

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: 3/8" BENTONITE CHIPS

Date started: 24-Jun , 20 08  
Date completed: 25-Jun , 20 08

7. Water Level  
Static water level: dry feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
<u>07-11-20</u>	<u>07-11-20</u>	<u>07-11-20</u>
<u>07-11-20</u>	<u>07-11-20</u>	<u>07-11-20</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC.  
Contractor

Address P. O. BOX 850  
Contractor

ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166

Signed Joseph C. Cumming  
By driller performing actual drilling on site or contractor

Date 6/27/2008