WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107189
Permit No.
Basin 162

NOTICE OF INTENT NO. 32656A

1. OWNER MICHAEL D'ERRICO
MAILING ADDRESS 4360 E SUSQUEHANNA ST.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4360 E SUSQUEHANNA ST

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T 20S N/S R 54E E NYE County
PERMIT NO. (Issued by Water Resources) 45-171-43 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other PLUG

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8" STEEL WELL 0-160				
--- PERFORATE FROM 160				
TO 50FT WITH HOLTZ				
PERFORATOR. PUMP				
BENTONITE GROUT FORM				
160 TO 50 FT WITH 1				
1/4 INCH TRMIE LINE.				
PUMP NEAT CEMENT GROUT				
FROM 50FT TO SURFACE.				
WGS84				
N 36 DEGREES 07.753				
W 115 DEGREES 56.045				

Date started 11/12/2008 , 19__
Date completed 11/12/2008 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
NOV 20 2008
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased EXISTING Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXST 8"				

Perforations:
Type perforation HOLTZ
Size perforation
From 160 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 77 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 11/18/2008

USE ADDITIONAL SHEETS IF NECESSARY