STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107196
Permit No.
Basin 214

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33355

1. OWNER Colton Corporation,LLC
MAILING ADDRESS P.O. Box 1599 Searchlight, NV 89046-1599

ADDRESS AT WELL LOCATION 2800' W of US 95, Searchlight,NV
Subdivision Name: County: Clark

2. LOCATION SW ¼ SE ¼ Sec 34 T 28l N OR 63 E
PERMIT/WAIVER No. 243-34-801-006
Issued by Water Resources Parcel No.

Latitude N35 27.555
Longitude W114 55.400
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Back Fill		0	8	8
Rock Sands & Gravel		8	50	42
Granite		50	240	190
Granite Fractured		240	290	50
Granite Fractured	X	290	350	60
Granite		350	425	75
Granite Fractured	X	425	525	100
Sands & Gravel	X	525	575	50
Limestone	X	575	620	45

Date started: August 4th, 20 08
Date completed: August25th, 20 08

9. WELL CONSTRUCTION
Depth Drilled 620 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.025	Inches	0	Feet	620	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		F480	0	620

Perforations:
Type of perforation Saw Cut
Size of perforation 1/8 x 6"

From	280	feet to	300	feet
From	320	feet to	340	feet
From	520	feet to	560	feet
From	580	feet to	600	feet
From		feet to		feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☒ Concrete Grout	0	to 50	☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 198 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	--	.5

DCNR/DWR RECEIVED
NOV 20 2008
LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling & Pump Service
Contractor
Address 530 E Larson Lane, Henderson 89044
Contractor
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ron Torok
By driller performing actual drilling on site or contractor
Date 11/10/2008

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY