STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107197
Permit No.
Basin 214

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34097

1. OWNER Public Right of Way (Clark County)
MAILING ADDRESS 500 S. Grand Central Pky
Las Vegas, NV 89103

ADDRESS AT WELL LOCATION Right of Way US95, 4miles S of Cal-Nev-Ari
Subdivision Name: County: Clark

2. LOCATION SW ¼ NW ¼ Sec 17 T 31 N S 64 E
PERMIT/WAIVER No. C1043 (Issued by Water Resources) 260-17-099-001 Parcel No.

Latitude N35 15' 08.7"
Longitude W114 52' 04.7"
UTM E ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	200	200
Cemented & Gravel		200	450	250
Sand & Gravel	x	450	885	435

DCNR/DWR RECEIVED
NOV 18 2008
LAS VEGAS OFFICE

Date started: 18-Oct, 20 08
Date completed: 9-Nov, 20 08

9. WELL CONSTRUCTION
Depth Drilled 885' Feet Depth Cased 885' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17	Inches	0	Feet	53	Feet
12.025	Inches	53	Feet	885	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.6250	24.70	.277	+1	885

Perforations:
Type of perforation Factory
Size of perforation .1250x4"
From 500 feet to 540 feet
From 790 feet to 850 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 53	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 450 to 880 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 425 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Estimated	200		12 hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling & Pump Service (Contractor)
Address 530 E Larson Ln, Henderson, NV 89044 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ron Tass (By driller performing actual drilling on site or contractor)
Date 11/10/2008

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY