STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107198
Permit No.
Basin 684

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62085

1. OWNER Dick & Debbie Lewis
MAILING ADDRESS 4615 Cactus Canyon
NW Reno, Nv 89510

ADDRESS AT WELL LOCATION 4615 Cactus Canyon
Reno, NV 89510
Subdivision Name: County: Washoe

2. LOCATION SE ¼ NW ¼ Sec 29 T 22N N/S R 21 E
PERMIT/WAIVER No. 076-150-10
Issued by Water Resources Parcel No.

Latitude N 39 44.978
Longitude W 119 39.450
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☒ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Trip in to 812 hit soft bottom.				
Blew air circulated down to 823				
hit metal. Tripped in mill but				
couldn't drill. We assume tool				
joint from previous driller.				
W.C.H.D. tag total depth at				
818 ft. Measured total depth at				
823 ft.from ground level				
develop/reconditionwell with				
air to clean.				
T.D. 823 ft				
N 39.749745				
W 119.656495 NAD27				
Original ⊕ log #32948				

Date started: 7-Jul, 20 08
Date completed: 14-Jul, 20 08

7. Water Level
Static water level: 775 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5.5	810	3 hrs

9. WELL CONSTRUCTION
Depth Drilled 823 Feet Depth Cased 823 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10.79	.156	+2	823

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout in place to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service LLC
Contractor
Address P.O. Box 60130 Reno, NV 89506
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 35387C
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 786
Signed
By driller performing actual drilling on site or contractor
Date 7/17/2008

RECEIVED JUL 21 2008 11:32 STATE ENGINEER'S OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY